

HONESTY . INTEGRITY . RESPECT . RESULTS

Narrative and response: Private use above ground fuel storage Prepared By : Randall Sly, Director of Construction Compliance, All County Paving

For All County Paving facilities located on GCG Real Estate Holding properties PCN 12-43-46-20-01-021-0032

1st TAC Comments 08/02/2024 : Planning Review Comments Response Cited

The All County Paving open storage facilities located on GCG Real Estate Holding property store non-commercial fuel products for the exclusive fueling of equipment and machinery related to offsite daily operations.

Fuel Supplier: Black Oil Inc. 9185 N.W. 96 St. Medley FL. 33178

No outside or retail commercial sale of fuel performed or proposed. Response - (Planning Comment 45 LDR Sec 4.3.3) No commercial metered fuel pumps are installed or proposed on site.

No underground vented tank systems installed or proposed on site. Response - (Planning Comment 72 LDR Sec 10.3.6) No public access to fuel proposed. Response - (Planning Comment 28 LDR Sec 2.4.6)

Specifications:

Fuel is stored in 500 Gallon UL142 Listed and Certified (MH12846) Double walled Flammable-Liquid vented tanks. Fuel tanks are below the ASTs greater than 550-gallon capacity threshold of DEP state regulation and inspection requirements. Response - (Planning Comment 24 LDR Sec 2.4.6)

Tanks and fuel yard conform to NFPA 30 requirements for flammable and combustible liquids. Response - (Planning Comment 24 LDR Sec 2.4.6)

Fuel yard location is obscured from public view and access

Fuel yard location meets minimum setback requirements Response - (Planning Comment 27 LDR Sec 2.4.6)

Fuel tanks are clearly labeled identifying content.

Fuel tanks are contained within a 5460-gallon (730 cubic foot) retention barrier for spill protection.

The fuel storage area incorporates required safety features including

Grounded tanks and pumps.

Emergency power shut off.

Fire extinguishers with High-Vis signage.

Fuel delivery pumps are powered only when in use.

Tank contents

High sulfur diesel (ULSD) for use exclusively in construction machinery.

Off-road diesel (Dyed ULSD) for use exclusively in construction equipment and machinery.

Gasoline (87) Regular for use exclusively in construction equipment and hand tools.

Safety:

The suppression systems are inspected annually by independent fire safety vendors and the City of Delray Fire Marshal. All County Paving staff perform daily inspections per the spill prevention requirements of county permit WP-2023-005 to operate within a wellfield.

M&M Asphalt Maintenance Inc., d/b/a All County Paving Office 561-588-0949 | Fax 561-588-2140 | 1180 SW 10th Street, Delray Beach, FL 33444

LICENSED, BONDED, INSURED, FDOT CERTIFIED

General Contractor: CGC1534510



HONESTY . INTEGRITY . RESPECT . RESULTS

Randall Sly Director of Construction Compliance All County Paving

11 22 2024 Date

attachments: Tank specification UL Listing SDS Valero Diesel Fuel Wellfield permit WP-2023-005

> M&M Asphalt Maintenance Inc., d/b/a All County Paving Office 561-588-0949 | Fax 561-588-2140 | 1180 SW 10th Street, Delray Beach, FL 33444

LICENSED, BONDED, INSURED, FDOT CERTIFIED

General Contractor: CGC1534510











ENGLISH

< Return to results :: Keyword: "MH12846"

Aboveground Flammable-liquid Tanks

UL Certified

DOCUMENT: EEEV.MH12846 · PRODUCT CODE (UL CCN): EEEV



Aboveground Flammable-liquid Tanks



MH12846



Tanks, Tanks, Tanks, Tanks, Tanks, Tanks, Tanks



PEE DEE TANK CO OF SOUTH CAROLINA L L C

GUIDE INFORMATION

Need More Information?

Looking for Guide Information documents and more? Product iQ offers professional level information and is free for most users.

Join Product iQ



SAFETY DATA SHEET

1. Identification			
Product identifier	DIESEL FUELS		
Other means of identification			
SDS number	102-GHS		
Synonyms	Diesel Fuel, Oltra Low Sulfur Diesel Fuel C	Fuel Oil No.2, High Sulfur Diesel Fuel, Low Sulfur ARB (California Air Resource Board) Diesel Fuel, Grade Diesel Fuel, X-1 Diesel Fuel, R5 ULSD, B5 ULS	
Recommended use	Motor Fuel Refinery feedstock.		
Recommended restrictions	None known.		
Manufacturer/Importer/Supplier/	Distributor information		
Manufacturer/Supplier General Assistance E-Mail Contact Person Emergency Telephone	Valero Marketing & Supply Company and A One Valero Way San Antonio, TX 78269-6000 210-345-4593 CorpHSE@valero.com Industrial Hygienist 24 Hour Emergency 866-565-5220 1-800-424-9300 (CHEMTREC USA)	ffiliates	
2. Hazard(s) identification			
Physical hazards	Flammable liquids	Category 3	
Health hazards	Acute toxicity, inhalation	Category 4	
	Skin corrosion/irritation	Category 2	
	Carcinogenicity	Category 2	
	Reproductive toxicity	Category 2	
	Specific target organ toxicity, repeated exposure	Category 2	
	Aspiration hazard	Category 1	
Environmental hazards	Hazardous to the aquatic environment, long-term hazard	Category 2	
OSHA defined hazards	Not classified.		
Label elements			

Signal word Hazard statement

Precautionary statement Prevention Flammable liquid and vapor. Harmful if inhaled. Causes skin irritation. Suspected of causing cancer. Suspected of damaging fertility or the unborn child. May cause damage to organs (blood, thymus, liver) through prolonged or repeated exposure. May be fatal if swallowed and enters airways.

Obtain special instructions before use. Do not handle until all safety precautions have been read and understood. Keep away from heat/sparks/open flames/hot surfaces. - No smoking. Keep container tightly closed. Ground/bond container and receiving equipment. Use explosion-proof electrical/ventilating/lighting equipment. Use only non-sparking tools. Take precautionary measures against static discharges. Do not breathe mist/vapors/spray. Wash thoroughly after handling. Wear protective gloves/protective clothing/eye protection/face protection. Use only outdoors or in a well-ventilated area.

Danger

Response

If skin irritation occurs: Get medical advice/attention. If inhaled: Remove person to fresh air and keep comfortable for breathing. If on skin (or hair): Take off immediately all contaminated clothing. Rinse skin with water/shower. If exposed or concerned: Get medical advice/attention. If swallowed: Immediately call a poison center/doctor. Take off contaminated clothing and wash before reuse. In case of fire: Use foam, carbon dioxide, dry powder or water fog for extinction.

Storage

Store locked up. Store in a well-ventilated place. Keep cool.

Disposal Hazard(s) not otherwise classified (HNOC) Dispose of contents/container in accordance with local/regional/national/international regulations. None known.

3. Composition/information on ingredients

Mixtures

Chemical name	CAS number	% 85 - 100	
Fuels, diesel, no. 2	68476-34-6		
Biodiesel - Fatty acid methyl esters	67762-38-3	0 - 10	
Fuels, diesel, C9-18-alkane branched and linear	1159170-26-9	0 - 5	
n-Nonane	111-84-2	1 - 3	
Octane (All isomers)	111-65-9	1 - 2	
Hexane (Other isomers)	96-14-0	0 - 1	
Naphthalene	91-20-3	0 - 1	
n-Heptane	142-82-5	0 - 1	
n-Hexane	110-54-3	0 - 1	

4. First-aid measures

4. I list-diu measures	
Inhalation	Move to fresh air. If breathing is difficult, give oxygen. If not breathing, give artificial respiration. Get medical attention.
Skin contact	Remove contaminated clothing and shoes. Wash off immediately with soap and plenty of water. Get medical attention if irritation develops or persists. Wash clothing separately before reuse. Destroy or thoroughly clean contaminated shoes. If high pressure injection under the skin occurs, always seek medical attention.
Eye contact	Immediately flush eyes with plenty of water for at least 15 minutes. Remove contact lenses, if present and easy to do. Continue rinsing. Get medical attention.
Ingestion	Rinse mouth thoroughly. Do not induce vomiting without advice from poison control center. Do not give mouth-to-mouth resuscitation. If vomiting occurs, keep head low so that stomach content does not get into the lungs. Never give anything by mouth to a victim who is unconscious or is having convulsions. Get medical attention immediately.
Most important symptoms/effects, acute and delayed	Irritation of nose and throat. Irritation of eyes and mucous membranes. Skin irritation. Unconsciousness. Corneal damage. Narcosis. Decrease in motor functions. Behavioral changes. Edema. Liver enlargement. Jaundice. Conjunctivitis. Proteinuria. Defatting of the skin. Rash. The toxicological properties of this product have not been thoroughly investigated. Use appropriate precautions. Hydrogen sulfide, a highly toxic gas, may be present. Signs and symptoms of overexposure to hydrogen sulfide include respiratory and eye irritation, dizziness, nausea, coughing, a sensation of dryness and pain in the nose, and loss of consciousness. Odor does not provide a reliable indicator of the presence of hazardous levels in the atmosphere.
Indication of immediate medical attention and special treatment needed	In case of shortness of breath, give oxygen. Keep victim warm. Keep victim under observation. Symptoms may be delayed. The toxicological properties of this material have not been fully investigated.
General information	If exposed or concerned: get medical attention/advice. Ensure that medical personnel are aware of the material(s) involved, and take precautions to protect themselves. Show this safety data sheet to the doctor in attendance. Wash contaminated clothing before re-use.
5. Fire-fighting measures	

Suitable extinguishing media

Water spray. Water fog. Foam. Dry chemical powder. Carbon dioxide (CO2).

Unsuitable extinguishing media	Do not use a solid water stream as it may scatter and spread fire.
Specific hazards arising from the chemical	The product is flammable, and heating may generate vapors which may form explosive vapor/air mixtures. Thermal decomposition or combustion may liberate toxic gases or fumes.
Special protective equipment and precautions for firefighters	demand breathing apparatus, protective clothing and face mask
Fire-fighting equipment/instructions	Wear full protective clothing, including helmet, self-contained positive pressure or pressure demand breathing apparatus, protective clothing and face mask. Withdraw immediately in case of rising sound from venting safety devices or any discoloration of tanks due to fire. Fight fire from maximum distance or use unmanned hose holders or monitor nozzles. Move containers from fire area if you can do it without risk. In the event of fire, cool tanks with water spray. Cool containers exposed to flames with water until well after the fire is out. For massive fire, use unmanned hose holders or monitor nozzles; if this is impossible, withdraw from area and let fire burn. Water runoff can cause environmental damage. Use compatible foam to minimize vapor generation as needed.
6. Accidental release meas	Sures
Personal precautions, protective equipment and emergency procedures	Keep unnecessary personnel away. Local authorities should be advised if significant spills cannot be contained. Keep upwind. Keep out of low areas. Ventilate closed spaces before entering. Do not touch damaged containers or spilled material unless wearing appropriate protective clothing. See Section 8 of the SDS for Personal Protective Equipment.
Methods and materials for containment and cleaning up	Eliminate all ignition sources (no smoking, flares, sparks, or flames in immediate area). Local authorities should be advised if significant spillages cannot be contained. Stop leak if you can do so without risk. This material is a water pollutant and should be prevented from contaminating soil or from entering sewage and drainage systems and bodies of water. Dike the spilled material, where this is possible. Prevent entry into waterways, sewers, basements or confined areas.
	Use non-sparking tools and explosion-proof equipment.
	Small Spills: Absorb spill with vermiculite or other inert material, then place in a container for chemical waste. Clean surface thoroughly to remove residual contamination. This material and its container must be disposed of as hazardous waste.
	Large Spills: Use a non-combustible material like vermiculite, sand or earth to soak up the product and place into a container for later disposal. Prevent product from entering drains. Do not allow material to contaminate ground water system. Should not be released into the environment.
Environmental precautions	Clean up in accordance with all applicable regulations.
	If facility or operation has an "oil or hazardous substance contingency plan", activate its procedures. Stay upwind and away from spill. Wear appropriate protective equipment including respiratory protection as conditions warrant. Do not enter or stay in area unless monitoring indicates that it is safe to do so. Isolate hazard area and restrict entry to emergency crew. Flammable. Review Firefighting Measures, Section 5, before proceeding with clean up. Keep all sources of ignition (flames, smoking, flares, etc.) and hot surfaces away from release. Contain spill in smallest possible area. Recover as much product as possible (e.g. by vacuuming). Stop leak if it can be done without risk. Use water spray to disperse vapors. Use compatible foam to minimize vapor generation as needed. Spilled material may be absorbed by an appropriate absorbent, and then handled in accordance with environmental regulations. Prevent spilled material from entering sewers, storm drains, other unauthorized treatment or drainage systems and natural waterways. Contact fire authorities and appropriate federal, state and local agencies. If spill of any amount is made into or upon navigable waters, the contiguous zone, or adjoining shorelines, contact the National Response Center at 1-800-424-8802. For highway or railways spills, contact Chemtrec at 1-800-424-9300.
7. Handling and storage	
۲ s v v f f f n n	Eliminate sources of ignition. Avoid spark promoters. Ground/bond container and equipment. These alone may be insufficient to remove static electricity. Wear personal protective equipment. Avoid breathing mist/vapors/spray. Avoid contact with eyes, skin, and clothing. Do not taste or swallow. Avoid prolonged exposure. Use only with adequate ventilation. Wash thoroughly after handling. The product is combustible, and heating may generate vapors which may form explosive vapor/air mixtures. DO NOT handle, store or open near an open lame, sources of heat or sources of ignition. Protect material from direct sunlight. Take precautionary measures against static discharges. All equipment used when handling the product nust be grounded. Use non-sparking tools and explosion-proof equipment. When using, do not eat, drink or smoke. Avoid release to the environment.

Flammable liquid storage. Do not handle or store near an open flame, heat or other sources of ignition. This material can accumulate static charge which may cause spark and become an ignition source. The pressure in sealed containers can increase under the influence of heat. Keep container tightly closed in a cool, well-ventilated place. Keep away from food, drink and animal feedingstuffs. Keep out of the reach of children.

8. Exposure controls/personal protection

Occupational exposure limits

US. OSHA Table Z-1 Limits for Air Contaminants (29 CFR 1910.1000)

Components	Туре	Value	
Naphthalene (CAS 91-20-3)	PEL	50 mg/m3	
		10 ppm	
n-Heptane (CAS 142-82-5)	PEL	2000 mg/m3	
		500 ppm	
n-Hexane (CAS 110-54-3)	PEL	1800 mg/m3	
		500 ppm	
Octane (All isomers) (CAS 111-65-9)	PEL	2350 mg/m3	
		500 ppm	

US. ACGIH Threshold Limit Values

Components	Туре	Value	Form	
Fuels, diesel, no. 2 (CAS 68476-34-6)	TWA	100 mg/m3	Inhalable fraction and vapor.	
Hexane (Other isomers) (CAS 96-14-0)	STEL	1000 ppm		
	TWA	500 ppm		
Naphthalene (CAS 91-20-3)	STEL	15 ppm		
	TWA	10 ppm		
n-Heptane (CAS 142-82-5)	STEL	500 ppm		
	TWA	400 ppm		
n-Hexane (CAS 110-54-3)	TWA	50 ppm		
n-Nonane (CAS 111-84-2)	TWA	200 ppm		
Octane (All isomers) (CAS 111-65-9)	TWA	300 ppm		

US. NIOSH: Pocket Guide to Chemical Hazards

Components	Туре	Value
Hexane (Other isomers) (CAS 96-14-0)	Ceiling	1800 mg/m3
,		510 ppm
	TWA	350 mg/m3
		100 ppm
Naphthalene (CAS 91-20-3)	STEL	75 mg/m3
		15 ppm
	TWA	50 mg/m3
		10 ppm
n-Heptane (CAS 142-82-5)	Ceiling	1800 mg/m3
		440 ppm
	TWA	350 mg/m3
		85 ppm
n-Hexane (CAS 110-54-3)	TWA	180 mg/m3
		50 ppm
n-Nonane (CAS 111-84-2)	TWA	1050 mg/m3
		200 ppm
Octane (All isomers) (CAS 111-65-9)	Ceiling	1800 mg/m3
		385 ppm
	TWA	350 mg/m3
		75 ppm

Biological limit values

ACGIH Biological Exposure Indices

Components	Value	Determinant	Specimen	Sampling Time
n-Hexane (CAS 110-54-3)	0.4 mg/l	2,5-Hexanedio n, without hydrolysis	Urine	*
	0.4 mg/l	2,5-Hexanedi - on, without hydrolysis		*
 For sampling details, plea 	ase see the source	document.		
Exposure guidelines				
US - California OELs: Skin	designation			
n-Hexane (CAS 110-54 US ACGIH Threshold Limi		Can be	absorbed throu	ugh the skin.
Fuels, diesel, no. 2 (CA Naphthalene (CAS 91-2 n-Hexane (CAS 110-54	20-3)	Can be	absorbed throu absorbed throu absorbed throu	ugh the skin.
Appropriate engineering controls	ventilation, or o	te general and local ext	aust ventilation	n. Use process enclosures, local exhaust porne levels below recommended exposure
Individual protection measures			t	
Eye/face protection	Wear safety gla	sses. If splash potential	exists, wear fu	ll face shield or chemical goggles.
Skin protection				en e
Hand protection	Wear chemical- supplier. Be awa	resistant, impervious glo are that the liquid may p	oves. Suitable g enetrate the glo	loves can be recommended by the glove oves. Frequent change is advisable.
Other	Full body suit ar	nd boots are recommende retardant protective cl	ded when hand	ling large volumes or in omorgonau
Respiratory protection	Use a properly f risk assessment anticipated expo respirator. If wor equipment shou trained personne	itted, air-purifying or air- indicates this is necess sure levels, the hazards kplace exposure limits t ld be worn. Proper resp el, based on the contam	fed respirator of ary. Respirator of the product or product or co inator selection inants, the dea	complying with an approved standard if a selection must be based on known or and the safe working limits of the selected omponents are exceeded, NIOSH approved should be determined by adequately ree of potential exposure and published e available for nonroutine and emergency
Thermal hazards	Wear appropriat	e thermal protective clo	thing, when neo	cessary.
General hygiene considerations	Consult supervis skin. Keep away the product. Pro	or for special handling i from food and drink. W	nstructions. Av	void contact with eyes. Avoid contact with ore breaks and immediately after handling er. Handle in accordance with good

9. Physical and chemical properties

Appearance	Liquid (may be dyed red).
Physical state	Liquid.
Form	Liquid.
Color	Clear. Straw.
Odor	Kerosene (strong).
Odor threshold	Not available.
pH	Not available.
Melting point/freezing point	-60.07 °F (-51.15 °C) Estimated
Initial boiling point and boiling range	325 - 700 °F (162.78 - 371.11 °C)
Flash point	> 100.0 °F (> 37.8 °C) Closed Cup
Evaporation rate	0.02
Flammability (solid, gas)	Not available.

Upper/lower flammability or exp	plosive limits
Flammability limit - lower (%)	0.4 %
Flammability limit - upper (%)	8 %
Explosive limit - lower (%)	Not available.
Explosive limit - upper (%)	Not available.
Vapor pressure	< 1 mm Hg (20°C)
Vapor density	3 (Air = 1)
Relative density	0.82 - 0.87
Relative density temperature	60 °F (15.56 °C)
Solubility(ies)	
Solubility (water)	Not available.
Partition coefficient (n-octanol/water)	Not available.
Auto-ignition temperature	494.96 °F (257.2 °C)
Decomposition temperature	Not available.
Viscosity	2 - 4.5 mm²/s
10. Stability and reactivity	
Reactivity	Stable at normal conditions.
Chemical stability	Stable under normal temperature conditions and recommended use.
Possibility of hazardous reactions	Hazardous polymerization does not occur.
Conditions to avoid	Heat, flames and sparks. Ignition sources. Contact with incompatible materials. Do not pressurize, cut, weld, braze, solder, drill, grind or expose empty containers to heat, flame, sparks, static electricity, or other sources of ignition; they may explode and cause injury or death.
Incompatible materials	Strong oxidizing agents.
Hazardous decomposition products	No hazardous decomposition products are known.
11. Toxicological informati	ion
Information on likely routes of ex	(posure

Ingestion May be fatal if swallowed and enters airways. Inhalation Harmful if inhaled. In high concentrations, vapors and spray mists are narcotic and may cause headache, fatigue, dizziness and nausea. Skin contact Causes skin irritation. Eye contact May cause eye irritation. Symptoms related to the Irritation of nose and throat. Irritation of eyes and mucous membranes. Skin irritation. physical, chemical and Unconsciousness. Corneal damage. Narcosis. Decrease in motor functions. Behavioral changes. Edema. Liver enlargement. Jaundice. Conjunctivitis. Proteinuria. Defatting of the skin. Rash. The toxicological characteristics toxicological properties of this product have not been thoroughly investigated. Use appropriate precautions. Information on toxicological effects

Acute toxicity

Harmful if inhaled. Harmful: may cause lung damage if swallowed. The toxicological properties of this material have not been fully investigated.

Components	Species	Test Results
Fuels, diesel, no. 2 (CAS 68476-34-6)		
Acute		
Inhalation		
LC50	Rat	4.1 mg/l, 4 hours

Components	Species	Test Results	
Naphthalene (CAS 91-20-3)			
Acute			
Dermal			
LD50	Rabbit	> 2 g/kg	
Oral			
LD50	Rat	490 mg/kg	
n-Heptane (CAS 142-82-5)			
Acute			
Inhalation			
LC50	Rat	103 mg/l, 4 Hours	
n-Hexane (CAS 110-54-3)			
Acute			
Oral LD50	Rat		
	Rat	28710 mg/kg	
n-Nonane (CAS 111-84-2) Acute			
Inhalation			
LC50	Rat	2200 mg// 4 Hours	
Octane (All isomers) (CAS 111-6		3200 mg/l, 4 Hours	
Acute	5-3)		
Inhalation			
LC50	Rat	118 mg/l, 4 Hours	
kin corrosion/irritation	Causes skin irritation.		
Serious eye damage/eye	Based on available data, the cla	ssification oritoria are not mot	
rritation		ssilication chiena are not met.	
Respiratory or skin sensitizatio	n		
Respiratory sensitization	Based on available data, the cla	ssification criteria are not met.	
Skin sensitization	Based on available data, the cla		
Germ cell mutagenicity	Based on available data, the cla	ssification criteria are not met.	
Carcinogenicity	Suspected of causing cancer.		
	International Agency for Research	ch on Cancer (IARC): Whole diesel engine exhaust – IARC Group	
	1. Exposure may cause lung cancer and also noted a positive association with an increased risk of bladder cancer.		
	Diesel exhaust has been reported to be an occupational hazard due to NIOSH-reported potential		
	carcinogenic properties.		
	Evaluation of Carcinogenicity		
Fuels, diesel, no. 2 (CAS Naphthalene (CAS 91-20		3 Not classifiable as to carcinogenicity to humans.	
NTP Report on Carcinogen		2B Possibly carcinogenic to humans.	
Naphthalene (CAS 91-20		Reasonably Anticipated to be a Human Carcinogen.	
Reproductive toxicity	Suspected of damaging fertility of	or the unborn child.	
	Napthalene interferes with embr	yo development in experimental animals at dose levels that cause	
	maternal toxicity. In humans, exc mother and fetus.	cessive exposure to this agent may cause hemolytic anemia in the	
pecific target organ toxicity -	Based on available data, the clas	ssification criteria are not met	
ingle exposure			
pecific target organ toxicity - epeated exposure	May cause damage to the following organs through prolonged or repeated exposure: Blood. Liver. Thymus.		
spiration hazard	May be fatal if swallowed and en	ters airways.	
hronic effects			
	Contains organic solvents which in case of overexposure may depress the central nervous system causing dizziness and intoxication. Repeated exposure to naphthalene may cause cataracts, allergic skin rashes, destruction of red blood cells, and anemia, jaundice, kidney and liver damage. Danger of serious damage to health by prolonged exposure. Prolonged or repeated overexposure may cause central nervous system, kidney, liver, and lung damage.		

Symptoms may be delayed. Hydrogen sulfide, a highly toxic gas, may be present. Signs and symptoms of overexposure to hydrogen sulfide include respiratory and eye irritation, dizziness, nausea, coughing, a sensation of dryness and pain in the nose, and loss of consciousness. Odor does not provide a reliable indicator of the presence of hazardous levels in the atmosphere. Toxicological properties of this material have not been fully investigated.

12. Ecological information

Ecotoxicity	E	co	to	xi	ic	ity
-------------	---	----	----	----	----	-----

Toxic to aquatic organisms, may cause long-term adverse effects in the aquatic environment

Ecoloxicity	I oxic to aqua	atic organisms, may cause long-term adver	se effects in the aquatic environment.
Components		Species	Test Results
Fuels, diesel, no. 2 (CAS 6	8476-34-6)		
Aquatic			
Acute			
Crustacea	EL50	Daphnia magna	68 mg/l, 48 hours
Fish	LL50	Oncorhynchus mykiss	65 mg/l, 96 hours
Naphthalene (CAS 91-20-3)		
Aquatic			
Crustacea	EC50	Water flea (Daphnia magna)	1.09 - 3.4 mg/l, 48 hours
Fish	LC50	Pink salmon (Oncorhynchus gorbuscha)	0.95 - 1.62 mg/l, 96 hours
n-Heptane (CAS 142-82-5)			
Aquatic			
Fish	LC50	Western mosquitofish (Gambusia affinis)	4924 mg/l, 96 hours
n-Hexane (CAS 110-54-3)			
Aquatic			
Fish	LC50	Fathead minnow (Pimephales promelas)	2.101 - 2.981 mg/l, 96 hours
Persistence and degradability	Not available.		
Bioaccumulative potential	Not available.		
Partition coefficient n-octa Hexane (Other isomers) (CA Octane (All isomers) (CAS 1 n-Heptane (CAS 142-82-5) n-Hexane (CAS 110-54-3) n-Nonane (CAS 111-84-2)	AS 96-14-0)	3.6 5.18 4.66 3.9	
. ,	No. 1	5.46	
Mobility in soil	Not available.		
Other adverse effects	Not available.		
13. Disposal consideration	ons		
Disposal instructions	waste collectio incinerator. Do	ordance with all applicable regulations. Thi hazardous waste. Dispose of this material n point. Incinerate the material under contri- not allow this material to drain into sewers ays or ditches with chemical or used contai	and its container to hazardous or specia olled conditions in an approved (water supplies. Do not contaminate
Hazardous waste code	D001: Waste Flammable material with a flash point <140 °F		
US RCRA Hazardous Waste			
Naphthalene (CAS 91-20	0-3)	U165	
Waste from residues / unused products	Dispose of in accordance with local regulations.		
Contaminated packaging	Offer rinsed packaging material to local recycling facilities.		
14. Transport information	1		
UN number	UN1202		
UN proper shipping name Diesel fue Transport hazard class(es)			
Class Subsidiary risk	Combustible Lic	quid	
Packing group	Ш		

y instructions, SDS and emergency procedures before handling. 3, T2, TP1
v instructions, SDS and emergency procedures before handling. EL
r instructions, SDS and emergency procedures before handling. EL
EL
instructions SDS and amorganous presedures to the survey
instructions, SDS and emergency procedures before handling. le. However, this product is a liquid and if transported in bulk covered under /78, Annex I.
0 CFR 707, Subpt. D)
1.0 % One-Time Export Notification only.
nces (29 CFR 1910.1001-1050)
FR 302.4)
LISTED
Act of 1986 (SARA) azard - No
azard - No
ard - No No card - No zard - No
ard - No No card - No

Chemical name		CAS number	% by wt.	
Naphthalene		91-20-3	0 - 1	
ther federal regulations				
	on 112 Hazardous Air Pollut	ants (HAPs) List		
Naphthalene (CAS 91-2 n-Hexane (CAS 110-54	-3)			
	on 112(r) Accidental Release	e Prevention (40 CFR	68.130)	
Not regulated.				
Safe Drinking Water Act (SDWA)	Not regulated.			
S state regulations	birth defects or other repr	contains chemicals kn oductive harm.	own to the State of California to cause cano	cer and
US. Massachusetts RT	K - Substance List			
Naphthalene (CAS n-Heptane (CAS 14 n-Hexane (CAS 110 n-Nonane (CAS 11 Octane (All isomers	2-82-5) D-54-3) 1-84-2)	Know Act		
Fuels, diesel, no. 2 Naphthalene (CAS n-Heptane (CAS 14 n-Hexane (CAS 110 n-Nonane (CAS 111 Octane (All isomers US. Pennsylvania Wor	91-20-3) 2-82-5) 0-54-3) 1-84-2)	o-Know Law		
Fuels, diesel, no. 2 Hexane (Other ison Naphthalene (CAS n-Heptane (CAS 14 n-Hexane (CAS 110 n-Nonane (CAS 111 Octane (All isomers US. Rhode Island RTK	ners) (CAS 96-14-0) 91-20-3) 2-82-5) 0-54-3) 1-84-2)) (CAS 111-65-9)			
Naphthalene (CAS n-Hexane (CAS 110				
US. California Proposition	65			
US - California Propos Benzene (CAS 71-4 Toluene (CAS 108-1	,	productive Toxicity (CRT): Listed substance	
ternational Inventories				
Country(s) or region	Inventory name		On inventory (ye	es/no) [;]
Australia	Australian Inventory of Ch	emical Substances (Al		No
Canada	Domestic Substances List	(DSL)		No
Canada	Non-Domestic Substances	s List (NDSL)		No
China	Inventory of Existing Cher	nical Substances in Ch	ina (IECSC)	No
Europe	European Inventory of Exi Substances (EINECS)	sting Commercial Che	mical	No
Europe	European List of Notified (Chemical Substances (ELINCS)	No
Japan	Inventory of Existing and I	New Chemical Substar	nces (ENCS)	N
Korea	Existing Chemicals List (E	CL)		No
New Zealand	New Zealand Inventory			No
Philippines	Philippine Inventory of Ch	emicals and Chemical	Substances	No

Country(s) or region

Inventory name

United States & Puerto Rico Toxic Substances Control Act (TSCA) Inventory

On inventory (yes/no)* Yes

*A "Yes" indicates this product complies with the inventory requirements administered by the governing country(s). A "No" indicates that one or more components of the product are not listed or exempt from listing on the inventory administered by the governing country(s).

16. Other information, including date of preparation or last revision

Issue date	13-May-2013
Revision date	23-May-2014
Version #	04
Further information	HMIS® is a registered trade and service mark of the NPCA.
NFPA Ratings	

Disclaimer

This material Safety Data Sheet (SDS) was prepared in accordance with 29 CFR 1910.1200 by Valero Marketing & Supply Co., ("VALERO"). VALERO does not assume any liability arising out of product use by others. The information, recommendations, and suggestions presented in this SDS are based upon test results and data believed to be reliable. The end user of the product has the responsibility for evaluating the adequacy of the data under the conditions of use, determining the safety, toxicity and suitability of the product under these conditions, and obtaining additional or clarifying information where uncertainty exists. No guarantee expressed or implied is made as to the effects of such use , the results to be obtained, or the safety and toxicity of the product in any specific application. Furthermore, the information herein is not represented as absolutely complete, since it is not practicable to provide all the scientific and study information in the format of this document, plus additional information may be necessary under exceptional conditions of use, or because of applicable laws or government regulations.



Department of Environmental Resources Management 2300 North Jog Road, 4th Floor West Palm Beach, FL 33411-2743 (561) 233-2400 FAX: (561) 233-2414 www.pbcgov.com/erm

> Palm Beach County Board of County Commissioners

Gregg K. Weiss, Mayor

Maria Sachs, Vice Mayor

Maria G. Marino

Michael A. Barnett

Marci Woodward

Sara Baxter

Mack Bernard

County Administrator

Verdenia C. Baker

"An Equal Opportunity Affirmative Action Employer"

A printed on sustainable and recycled paper

August 3, 2023

CERTIFIED MAIL

Mr. Kenneth Goldberg, President GCG Real Estate Holdings, LLC 1088 SW 10th Street Delray Beach, FL 33444

Dear Mr. Goldberg:

SUBJECT: PERMIT TO OPERATE WITHIN WELLFIELD ZONE FOR ALL COUNTY PAVING; 1088 SW 10TH STREET, DELRAY BEACH; ERM FILE NO. 4-12-12-3620-374

Enclosed is the subject permit. Read through the permit conditions carefully. Should you object to any of the permit conditions, you must submit your objections in writing to the Department of Environmental Resources Management (ERM) within 20 days. If no objection to this permit is received, you will be deemed to have accepted the permit and all the attached terms and conditions. This permit shall become effective 20 days from the Date of Issue. In addition, a sample inspection log is enclosed for your use.

Should you have any questions or comments regarding the terms and conditions of the permit, please contact Samantha Pucci at (561) 233-2523.

Sincerely,

John Reiser Environmental Program Supervisor Resources Protection

BF:JR:SP Enclosures cc: (with enclosures) Hassan Hadjimiry, PE, Utilities Director City of Delray Beach



Department of Environmental Resources Management 2300 North Jog Road, 4th Floor West Palm Beach, FL 33411-2743 (561) 233-2400 FAX: (561) 233-2414 www.pbcgov.com/erm

Palm Beach County Board of County Commissioners

Gregg K. Weiss, Mayor

Maria Sachs, Vice Mayor

Maria G. Marino

Michael A. Barnett

Marci Woodward

Sara Baxter

Mack Bernard

County Administrator

Verdenia C. Baker

"An Equal Opportunity Affirmative Action Employer"

printed on sustainable and recycled paper

PERMIT TO OPERATE WITHIN A WELLFIELD ZONE

OWNER/AGENT: Kenneth Goldberg President

ERM FILE NO. 4-12-12-3620-374 PERMIT NO. WP-2023-005

PERMITTEE/ADDRESS:

GCG Real Estate Holdings, LLC 1088 SW 10th Street Delray Beach, FL 33444

FACILITY NAME/ADDRESS: All County Paving 1180 SW 10th Street Delray Beach, FL 33444

This permit is issued under the provisions of the Unified Land Development Code, Article 14.B., Wellfield Protection. The above named Permittee is hereby authorized to operate the facility shown on the application and approved drawings, plans, documents and/or specifications attached hereto or on file at the Department of Environmental Resources Management (ERM) and made a part hereof and specifically described below. If no objection to this permit is received within 20 days, Permittee will be deemed to have accepted the permit and all the attached terms and conditions.

DESCRIPTION OF BUSINESS: Paving contractor and construction office. Regulated Substances are described in Exhibit 1 and include gasoline, waste oil and diesel.

DESIGNATED PUBLIC UTILITY: City of Delray Beach Telephone (561) 243-7101

> Issued this day of (2023 PALM BEACH COUNTY DEPARTMENT OF ENVIRONMENTAL RESOURCES MANAGEMENT

0 ne Bonnie Finneran, Environmental Director

Resources Protection

GENERAL CONDITIONS

PERMIT NO. WP-2023-005

- 1. The terms, conditions, requirements, limitations and restrictions set forth herein are "Permit Conditions" and as such are accepted by and binding upon the Permittee and enforceable pursuant to Unified Land Development Code, Article 14.B., Wellfield Protection. ERM will review this permit periodically and may revoke or revise the permit, initiate administrative action, and/or initiate judicial action for any violation of the Permit Conditions by the Permittee, its agents, employees or representatives.
- 2. This permit is valid only for the specific uses set forth in the permit application. Any deviation from the approved uses or conditions of this permit may constitute grounds for revocation and enforcement action by ERM.
- 3. The issuance of this permit does not convey any vested rights or exclusive privileges, nor does it authorize any injury to public or private property or any invasion of personal rights, nor any violations of Federal, State or local laws or regulations.
- 4. This permit must be available for inspection on Permittee's premises during the entire life of the permit.
- 5. By accepting this permit, the Permittee understands and agrees that all records, notes, monitoring data and other information relating to the construction or operation of this permitted facility that are submitted to ERM may be used as evidence in any enforcement proceeding arising under ERM rules and regulations, except where prohibited by Section 403.111, Florida Statutes.
- 6. The Permittee agrees to comply with the provisions of Article 14.B.
- 7. By accepting this permit, the Permittee agrees to allow authorized ERM personnel access to the permitted facility at reasonable times for the purposes of inspection, record keeping review, and testing to determine compliance with the conditions of this permit and ERM rules and regulations.
- 8. This permit does not constitute a waiver of or approval of any other department permit or license that may be required for aspects of the facility not addressed in the permit.
- 9. In the event that the Permittee is temporarily unable to comply with any of the conditions of the permit, the Permittee shall notify ERM within 24 hours of the cause and nature of non-compliance, period of non-compliance, and measures taken to correct and prevent reoccurrence of the problem. The Permittee shall be responsible for any and all damages which may result and may be subject to enforcement action or revocation or revision of the permit.
- 10. Any new owner or operator of a permitted facility shall apply to ERM for a transfer of permit within 60 days after sale or legal transfer. The transferor shall remain liable for performance in accord with the permit until the transferee applies for and is granted transfer of the permit.

GENERAL CONDITIONS (continued)

PERMIT NO. WP-2023-005

- 11. This permit shall be valid until further notice from ERM. Commencing in the October following permit issuance, the Permittee shall pay to the Palm Beach County Board of County Commissioners an annual permit fee according to the Schedule of Fees for ERM.
- 12. The Permittee agrees to operate this facility in such a manner as to minimize the risk of release of Regulated Substances to the environment.
- 13. The Permittee shall report by telephone any spill of a Regulated Substance in excess of 5 gallons, if liquid, or 25 pounds, if solid, to the Palm Beach County Health Department and designated public utility within 1 hour and to ERM within 24 hours of discovery of the spill.
- 14. The Permittee shall commence cleanup of a spill of a Regulated Substance immediately upon discovery of the spill. A full written report including the steps taken to contain and cleanup the spill shall be submitted to ERM within 15 days of discovery of the spill.
- 15. The Permittee shall inspect containers used for storing Regulated Substances on every day of operation. A record of the daily inspections shall be maintained at the facility.
- 16. Upon request of ERM, the Permittee shall furnish all records or reports required by this permit. The Permittee shall retain at the facility copies of all records or reports required by this permit. These records or reports shall be retained for at least 3 years from the date of origination or permit issuance.

EXHIBIT 1

Regulated Substances

Regulated Substances are substances that may cause significant harm to human health and the environment (including surface and groundwater). Article 14.B. regulates the storage, handling, use and production of Regulated Substances which may impair present and future drinking water supplies. Substances and materials from the following categories that are stored, handled, used or produced at the facility are considered to be Regulated Substances.

Acid and basic cleaning solutions Antifreeze and coolants Arsenic and arsenic compounds Bleaches and peroxides Brake and transmission fluids Brine solution Casting & Foundry chemicals Caulking agents and sealants Cleaning solvents Corrosion and rust prevention solutions Cutting fluids Degreasing and parts cleaning solvents Disinfectants Electroplating solutions Explosives Fertilizers Fire extinguishing chemicals Food processing wastes Formaldehyde Fuels and fuel additives Glues, adhesives and resins Greases Hazardous waste Hydraulic fluid Indicators Industrial and commercial janitorial supplies Industrial process chemicals Industrial sludges and stillbottoms Inks, printing and photocopying chemicals Laboratory chemicals Liquid storage batteries

Medical, pharmaceutical, dental, veterinary and hospital solutions Mercury and mercury compounds Metal finishing solutions Oils Paints, primers, thinners, dyes, stains, wood preservatives, varnishing and cleaning compounds Painting solvents PCB's Pesticides and herbicides Plastic resins, plasticizers and catalysts Photo development chemicals Poisons Polishes Pool chemicals Processed dust and particulates Radioactive sources Reagents and standards Refrigerants Roofing chemicals and sealers Sanitizers, disinfectants bactericides and algaecides Soaps, detergents and surfactants Solders and fluxes Stripping compounds Tanning industry chemicals Transformer and capacitor oils/fluids Waste oils and antifreeze Water and wastewater treatment chemicals