

Photometrics Calculation Software Generated Luminaire Schedule									
Symbol	Qty	Label	Arrangement	Lum. Lumens	Arr. Lum. Lumens	LLF	Lum. Watts	Arr. Watts	
⬢	1	F	Single	12929	12929	0.900	86	86	
⬢	2	F-E	Single	12929	12929	0.900	86	86	
⬢	18	S	Single	3542	3542	0.900	28	28	
⬢	7	SA	Single	7527	7527	0.900	63	63	
⬢	1	SB	Single	9180	9180	0.900	63	63	
⬢	2	SC	Single	9625	9625	0.900	63	63	
⬢	1	SD	Single	7607	7607	0.900	63	63	
⬢	2	SE	Twin	52218	104436	0.900	481	962	
⬢	3	SF	Twin	46106	92212	0.900	481	962	
⬢	3	SG	Single	15528	15528	0.900	125	125	
⬢	7	SL	Single	25571	25571	1.000	183.1	183.1	
⬢	5	WA	Single	4874	4874	0.900	34	34	
⬢	4	WB	Single	4942	4942	0.900	34	34	
⬢	1	WC	Single	5007	5007	0.900	34	34	

Calculation Summary									
Label	CalcType	Units	Avg	Max	Min	Avg/Min	Max/Min	LV Ratio	
AUTOMOTIVE FRONT LINE	Illuminance	Fc	32.66	77.7	5.4	6.05	14.39	N.A.	
OLD DIXIE HIGHWAY	Illuminance	Fc	2.21	3.7	0.6	3.68	6.17	N.A.	
PARKING LOT	Illuminance	Fc	3.94	47.5	1.0	3.94	47.50	N.A.	
PROPERTY LINE AT 6' AFG	Illuminance	Fc	0.13	0.36	0.02	6.50	18.00	N.A.	
RAMP	Illuminance	Fc	26.59	34.8	10.1	2.63	3.45	N.A.	
RoadOpt_1_Illum	Illuminance	Fc	1.54	3.66	0.25	6.16	14.64	N.A.	
RoadOpt_1_Luminance	Luminance	Cd/Sq.m	1.20	3.06	0.47	2.55	6.51	N.A.	
RoadOpt_1_Veil_Lum	Luminance	Cd/Sq.m	0.14	0.33	0.02	7.00	16.50	0.28	
SIDEWALK	Illuminance	Fc	1.07	2.2	0.5	2.14	4.40	N.A.	



