



A. REFER TO SHEET **A-1** FOR DOOR SIZES AND HARDWARE.

B. SEE SHEET **603 & 604** FOR ADDITIONAL ACCESSIBILITY REQUIREMENTS

C. MEANS OF EGRESS PATH AND EXIT DISCHARGE SHALL BE ILLUMINATED AT ALL TIMES WHILE THE BUILDING IS OCCUPIED. MINIMUM LIGHT LEVEL SHALL BE 1 FOOT CANDLE. SEE ELECTRICAL DRAWINGS FOR EMERGENCY AND EXIT LIGHTING.

D. EXIT SIGNS SHALL BE WORDED "EXIT" IN LETTERS HAVING A PRINCIPLE STROKE OF NOT LESS THAN 3/4" WIDE AND AT LEAST 6" HIGH, AND SHALL CONFORM TO CODES AND/OR APPLICABLE REGULATIONS. EXIT SIGNS SHALL BE INTERNALLY ILLUMINATED (MIN 60 MINUTE) AND PROVIDED WITH TWO SEPARATE POWER SUPPLIES. SEE ELECTRICAL DRAWINGS FOR LOCATIONS AND ADDITIONAL INFORMATION.

E. EXIT DOORS MUST BE OPENABLE FROM EGRESS SIDE WITHOUT USE OF A KEY, SPECIAL KNOWLEDGE OR EFFORT.

F. SEE ELECTRICAL AND FIRE ALARM DRAWINGS FOR FIRE ALARM, HORN, STROBES AND OTHER FIRE ALARM DEVICES.

1	BREAKAWAY AUTOMATIC SLIDING DOORS WITH MOTION SENSORS. INSTALL EXIT SIGN, INTERNATIONAL SYMBOL OF ACCESSIBILITY ON OR ADJACENT TO BUILDING ENTRANCE PER. PLACE PER CODE OFFICIAL. SEE DOOR SCHEDULE FOR ADDITIONAL INFORMATION.
2	BARRIER FREE EXIT DOOR AND CONCRETE LANDING, EACH GRADE LEVEL. BARRIER FREE EXTERIOR EXIT DOOR SHALL BE MARKED WITH EXIT SIGN WITH THE WORD "EXIT". PLACE PER CODE OFFICIAL.
3	GENERAL CONTRACTOR TO PROVIDE AND INSTALL OCCUPANT LOAD SIGN(s). POSTED IN CONSPICUOUS LOCATION AS DIRECTED BY THE LOCAL BUILDING INSPECTOR. VERIFY QUANTITY, VERBAGE, AND FINAL LOCATIONS WITH THE INSPECTOR ON SITE.
4	GENERAL CONTRACTOR TO PROVIDE AND INSTALL ALLOWABLE FLOOR LIVE LOAD SIGN(s). POSTED IN CONSPICUOUS LOCATION AS DIRECTED BY THE LOCAL BUILDING INSPECTOR. VERIFY QUANTITY, VERBAGE, AND FINAL LOCATIONS WITH THE INSPECTOR ON SITE.
5	LOCATION OF FIRE PROTECTION SPRINKLER SYSTEM RISER.
6	EXISTING ELECTRICAL ROOM TO REMAIN.

FLORIDA BUILDING CODE 6TH EDITION (2017)
FLORIDA FIRE PREVENTION CODE 6TH EDITION (2017) - FL SPECIFIC NFPA 1 FIRE CODE 2015
and FL SPECIFIC NFPA 101 LIFE SAFETY CODE 2015.

- LEGEND:**
- | | |
|-------------|--|
| $O_{(ABC)}$ | PROPOSED FIRE EXTINGUISHER LOCATION (FOR USE ON TYPE A & B C FIRES) - COORDINATE FINAL LOCATIONS WITH FIRE AUTHORITY HAVING JURISDICTION AND LUCKY'S |
| $O_{(K)}$ | PROPOSED FIRE EXTINGUISHER LOCATION (FOR USE ON GREASE FIRES) - COORDINATE FINAL LOCATIONS WITH FIRE AUTHORITY HAVING JURISDICTION AND LUCKY'S |
- NOTE: FIRE EXTINGUISHER LOCATIONS AND QUANTITIES SHOWN FOR BID REFERENCE ONLY.
THE FINAL LOCATIONS AND QUANTITIES SHALL BE AS APPROVED BY THE LOCAL FIRE DEPARTMENT REQUIREMENTS.

WDPARTNERS.COM

**LUCKY'S MARKET
DELRAY COMMONS
5030 W. ATLANTIC AVENUE
DELRAY BEACH, FL**

GO.2

0012

Printed: 10/3/2019 8:45 AM (wda09) Plotted: 10/3/2019 8:50

01 **LIFE SAFETY PLAN**
SCALE: 1/8" = 1'-0"

LIFE SAFETY PLAN AND NOTES

GO.2