

**Mission:**

To protect, promote & improve the health of all people in Florida through integrated state, county & community efforts.



**Rick Scott**  
Governor

**John H. Armstrong, MD, FACS**  
State Surgeon General & Secretary

**Vision:** To be the Healthiest State in the Nation

## Notification of Acceptance of Use of a General Permit

**Permittee:**

John Morgan  
Director of Environmental service  
City of Delray Beach  
434 S. Swinton Avenue  
Delray Beach, FL 33444  
[morgan@mydelraybeach.com](mailto:morgan@mydelraybeach.com)

**Permit Number:** 138274-455-DSGP**Issue Date:** 02/03/2016**Expiration Date:** 02/02/2021**County:** Palm Beach**Project Name:** Marine Way (Canal St) WM Improvements**Water Supplier:** City of Delray Beach**PWS ID:** 4500351

Dear Mr. Morgan:

On February 1, 2016 the Florida Department of Health-Palm Beach County, as an approved local program of the Florida Department of Environmental Protection, received a "Notice of Intent to Use the General Permit for Construction of Water Main Extensions for PWSs" [DEP Form No. [62-555.900\(7\)](#)], under the provisions of Rule [62-4.530](#) and Chapter [62-555](#), Florida Administrative Code (F.A.C.). The proposed project includes :

**Construction of approximately 432 LF of 8" DIP water main to provide service for eight single family residences located in the right of way of Canal Street in the City of Delray Beach, Florida.**

Based upon the submitted Notice and accompanying documentation, this correspondence is being sent to advise that the Department does not object to the use of such general permit at this time. Please be advised that the permittee is required to abide by Rule [62-555.405, F.A.C.](#), all applicable rules in Chapters [62-4](#), [62-550](#), [62-555](#), F.A.C., and the General Conditions for All General Drinking Water Permits (found in [62-4.540, F.A.C.](#)).

When any existing asbestos cement (AC) pipes are replaced under this permit, the permittee shall do so in accordance with the applicable rules of the Federal Asbestos Regulation and Florida DEP requirements. For specific requirements applicable to AC pipes, the permittee should contact the Air and Waste Management section managers prior to commencing any such activities at (561) 837-5900 #3. Please be aware that a notification is required to be submitted to the Department for a regulated project.

The permittee shall comply with all sampling requirements specific to this project. These requirements are attached for review and implementation. Pursuant to Rule [62-555.345, F.A.C.](#), the permittee shall submit a certification of construction completion [DEP Form No. [62-555.900\(9\)](#)] to the Department and obtain approval, or clearance, from the Department before placing any water main extension constructed under this general permit into operation for any purpose other than disinfection or testing for leaks.

**Florida Department of Health**

Palm Beach County, Division of Environmental Public Health  
P.O. Box 29, 800 Clematis Street, West Palm Beach, FL 33402  
PHONE: 561-837-5900 • FAX: 561-837-5294

[www.FloridasHealth.com](http://www.FloridasHealth.com)

TWITTER:HealthyFLA

FACEBOOK:FLDepartmentofHealth

YOUTUBE: fldoh

PERMITTEE: City Of Delray Beach  
John Morgan, City of Delray Beach

Permit/Certification No.: 138274-455-DSGP

Within 30 days after the sale or legal transfer of ownership of the permitted project that has not been cleared for service in total by the Department, both the permittee and the proposed permittee shall sign and submit an application for transfer of the permit using Form 62-555.900(8), F.A.C., with the appropriate fee. The permitted construction is not authorized past the 30-day period unless the permit has been transferred.

This permit will expire five years from the date of issuance. If the project has been started and not completed by that time, a new permit must be obtained before the expiration date in order to continue work on the project, per Rule 62-4.030, F.A.C.

Sincerely,  
For the Division Director



---

Darrel J. Graziani, P.E., R.S.  
Environmental Administrator – Water Programs  
Environmental Public Health

DG/JH/KB

c: Project Engineer: Isaac Kovner, P.E.  
Utility: Same

**Civil Penalty May Be Incurred**  
**if this project is placed into operation before obtaining a clearance from this office.**

Requirements for clearance upon completion of projects are as follows:

**1) Clearance Form**

Submission of a fully completed Department of Environmental Protection (DEP) Form 62-555.900(9) *Certification of Construction Completion and Request for Clearance to Place Permitted PWS Components into Operation*.

**2) Record Drawings, if deviations were made**

Submission of the portion of record drawings showing deviations from the DEP construction permit, including preliminary design report or drawings and specifications, if there are any deviations from said permit (Note that it is necessary to submit a copy of only the portion of record drawings showing deviations and not a complete set of record drawings.).

**3) Bacteriological Results**

Copies of satisfactory bacteriological analysis (a.k.a. Main Clearance), taken within sixty (60) days of completion of construction, from locations within the distribution system or water main extension to be cleared, in accordance with Rules 62-555.315(6), 62-555.340, and 62-555.330, F.A.C. and American Water Works Association (AWWA) Standard C 651-92, as follows:

- Connection to an existing system
- The end point of the proposed addition
- Any water lines branching off a main extension
- Every 1,200 feet on straight runs of pipe

Each location shall be sampled on two consecutive days, with sample points and chlorine residual readings clearly indicated on the report. A sketch or description of all bacteriological sampling locations must also be provided. **All samples shall be collected by an employee of a state certified laboratory or a certified operator and be reported on DEP Reporting Format 62-550.730.**

For further clarification contact:  
Jay Hardman, P.E.  
Florida Department of Health Palm Beach  
Plan Review & Permit Section  
800 Clematis Street, 4<sup>th</sup> Floor  
West Palm Beach, FL 33401  
561-837-5900 #5