



May 26, 2023

Patrick A. Figurella, PE
City Engineer
100 NW First Avenue
Delray Beach, FL 33444

**Re: 25-27 SE 3rd Avenue – Bar 32 - Class V TAC ID-1167
Water Usage Requirements**

Dear Mr. Figurella:

This letter is to inform you of the existing and proposed water demands for the above referenced project for the purpose of obtaining a capacity letter. Based on F.A.C. Chapter 64E-6, Table 1, the following flows are provided:

LAND USE	DEMAND	UNIT	DEMAND RATE	GPD
Bank	8,397	SF	15 GPD / SF	1,260
Restaurant	337	Seat	40 GPD / Seat	13,480

Please contact me if you have any questions.

Very truly yours,

KIMLEY-HORN AND ASSOCIATES, INC.

This item has been digitally signed and sealed by Justin Thompson, PE, on 05/26/2023.

Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

05/26/2023

Justin Thompson, P.E.