

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC POOL AND BATHING PLACE  
INSPECTION REPORT



1 of 2

**Facility Information**

**RESULT: Satisfactory**

Permit Number: 50-60-01905  
Name of Facility: Pompey Park - Pool  
Address: 1102 NW 3 Street  
City, Zip: Delray Beach 33444

**Correct By: None**  
**Re-Inspection Date: None**

Type: Public Pool > 25000 Gallons  
Owner: Pompey Park  
Person In Charge: Smith, Gerard      Phone: (561) 243-7358  
PIC Email:  
Pool Operator: Smith, Gerard      Phone: (561) 243-7079

**Inspection Information**

Purpose: Routine  
Inspection Date: 12/6/2018

Begin Time: 09:00 AM  
End Time: 09:50 AM

**Additional Information**

22. Free Chlorine ..... 2.7	VOLUME ..... 220585
23. pH ..... 7.6	POOL LOAD ..... 122
24. Chlor. Stabilizer ..... 10	FLOW RATE ..... 612
33. Flowmeter ..... 630	NIGHT SWIM ..... No
34. Thermometer ..... 84	FILTER TYPE ..... SP

*Items checked are not in compliance with Chapter 386 or 514, Florida Statutes, or Chapter 64E-9 or 64E-10, Florida Administrative Code. These violations must be corrected by the date indicated to avoid closure, administrative fines, or other legal actions. Florida Building Code (FBC) violations are reported to the local building official, and depending upon risk severity, the Department of Health may close the pool or rescind the operating permit.*

**Violation Markings**

POOL AREA	17. Rules Posted	32. Vacuum Cleaner-FBC
1. Water Clarity/Algae Control	18. Certification	33. Flowmeter
2. Deck/Walkways	SANITARY FACILITIES	34. Thermometer
3. Tile/Pool Finish	19. Supplies 64E-10, FAC	35. Pressure/Vacuum Gauge
4. Depth Markers-FBC	20. Clean 64E-10, FAC	36. Equip. Room
5. Handrail/Ladder-FBC	WATER QUALITY	37. Cross Connection
6. Step Markings-FBC	21. Approved Test Kit	38. Gas Chlorine Eq.-FBC
7. Suction Outlets-514.0315(1)	22. Free Chlor./Brom.	39. Waste Water - FBC
8. Gutter Grates/Skimmer-FBC	23. pH	40. D.E. Separator-FBC
9. Lighting	24. Chlor. Stabilizer	41. Other Equipment
10. No Dive Markings-FBC	25. Spa Requirements-ORP	42. Equip. Change-FBC
11. Diving Board-FBC	EQUIPMENT ROOM	43. Approved Chemicals
12. Pool Cover	26. Wading Pool-Quick Dump	44. Maintenance Log
13. Pool Side Shower-FBC	27. Water Level/Control	45. Inspection Posted
POOL SAFETY	28. Disinfection Feeder/Generator	46. Safety-514.0315(2)
14. Life Hook(s) w/Pole	29. pH Feeder	47. Fences/Gates- FBC
15. Life Ring(s) w/Rope	30. Chem. Container Label-FBC	48. Other
16. Safety Line	31. Filter / Pump	49. Other

**NOTE:** It is unlawful to modify a public pool or its equipment without prior approval from the local building department and submitting an application to DOH.

Inspector Signature:

*Not 3*

Client Signature:

*Email*

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC POOL AND BATHING PLACE  
INSPECTION REPORT



2 of 2

**General Comments**

File#:

Gate Code#:

Facility Access Key#:

Equipment Access#:

Main Drain Grate:

SVRS:

Audit:

Chipped areas present on pool deck - Repair deck areas that are chipped or cracked.

Email Address(es): smithg@mydelraybeach.com

DOH Web Page For Pools: <http://www.floridahealth.gov/environmental-health/swimming-pools/index.html>

**Violations Comments**

No Violation Comments Available

Inspection Conducted By: Natalie Zorzi (004171)

Inspector Contact Number: Work: (561) 274-3187 ex.

Print Client Name:

Date: 12/6/2018

Inspector Signature:

Client Signature:

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC POOL AND BATHING PLACE  
INSPECTION REPORT



1 of 2

**Facility Information**

**RESULT: Satisfactory**

Permit Number: 50-60-01906  
Name of Facility: Pompey Park - WADER  
Address: 1102 NW 3 Street  
City, Zip: Delray Beach 33444

**Correct By: None**  
**Re-Inspection Date: None**

Type: Wading Pool  
Owner: Pompey Park  
Person In Charge: Smith, Gerard Phone: (561) 243-7358  
PIC Email:  
Pool Operator: Smith, Gerard Phone: (561) 243-7079

**Inspection Information**

Purpose: Routine  
Inspection Date: 12/6/2018

Begin Time: 09:50 AM  
End Time: 10:25 AM

**Additional Information**

22. Free Chlorine ..... 2.9	VOLUME ..... 2614
23. pH ..... 7.8	POOL LOAD ..... 30
24. Chlor. Stabilizer ..... 3	FLOW RATE ..... 45
33. Flowmeter ..... 55	NIGHT SWIM .....
34. Thermometer ..... 82	FILTER TYPE ..... SP

*Items checked are not in compliance with Chapter 386 or 514, Florida Statutes, or Chapter 64E-9 or 64E-10, Florida Administrative Code. These violations must be corrected by the date indicated to avoid closure, administrative fines, or other legal actions. Florida Building Code (FBC) violations are reported to the local building official, and depending upon risk severity, the Department of Health may close the pool or rescind the operating permit.*

**Violation Markings**

POOL AREA	17. Rules Posted	32. Vacuum Cleaner-FBC
1. Water Clarity/Algae Control	18. Certification	33. Flowmeter
2. Deck/Walkways	SANITARY FACILITIES	34. Thermometer
3. Tile/Pool Finish	19. Supplies 64E-10, FAC	35. Pressure/Vacuum Gauge
4. Depth Markers-FBC	20. Clean 64E-10, FAC	36. Equip. Room
5. Handrail/Ladder-FBC	WATER QUALITY	37. Cross Connection
6. Step Markings-FBC	21. Approved Test Kit	38. Gas Chlorine Eq.-FBC
7. Suction Outlets-514.0315(1)	22. Free Chlor./Brom.	39. Waste Water - FBC
8. Gutter Grates/Skimmer-FBC	23. pH	40. D.E. Separator-FBC
9. Lighting	24. Chlor. Stabilizer	41. Other Equipment
10. No Dive Markings-FBC	25. Spa Requirements-ORP	42. Equip. Change-FBC
11. Diving Board-FBC	EQUIPMENT ROOM	43. Approved Chemicals
12. Pool Cover	26. Wading Pool-Quick Dump	44. Maintenance Log
13. Pool Side Shower-FBC	27. Water Level/Control	45. Inspection Posted
POOL SAFETY	28. Disinfection Feeder/Generator	46. Safety-514.0315(2)
14. Life Hook(s) w/Pole	29. pH Feeder	47. Fences/Gates- FBC
15. Life Ring(s) w/Rope	30. Chem. Container Label-FBC	48. Other
16. Safety Line	31. Filter / Pump	49. Other

**NOTE:** It is unlawful to modify a public pool or its equipment without prior approval from the local building department and submitting an application to DOH.

Inspector Signature:

Client Signature:

*[Signature]*

*[Signature]*

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC POOL AND BATHING PLACE  
INSPECTION REPORT



2 of 2

**General Comments**

File#:  
Gate Code#:  
Facility Access Key#:  
Equipment Access#:  
Main Drain Grate:  
SVRS:  
Audit:

Chipped areas present on pool deck - Repair deck areas that are chipped or cracked.

Email Address(es): smithg@mydelraybeach.com

DOH Web Page For Pools: <http://www.floridahealth.gov/environmental-health/swimming-pools/index.html>

**Violations Comments**

No Violation Comments Available

Inspection Conducted By: Natalie Zorzi (004171)  
Inspector Contact Number: Work: (561) 274-3187 ex.  
Print Client Name:  
Date: 12/6/2018

Inspector Signature:

Client Signature: