



Gregory B. Medina  
FL REG. # AR 93534  
DATE 03-04-19  
CONTRACT # 2019  
NOT A PART OF THE CONTRACT. THIS DOCUMENT  
REPRODUCED BY ANY FORMS WITHOUT THE  
WRITTEN PERMISSION OF GRIECO DELRAY FORD



5001 S.W. 3RD AVENUE, SUITE F-5  
FORT LAUDERDALE, FLORIDA 33315  
T: 954.713.6101  
C: 954.812.6680  
E: GREGORY@CBMARCHITECTURE.COM  
WWW.CBMARCHITECTURE.COM

DRAWING ISSUE DATES:

SECOND FLOOR:  
LIFE SAFETY PLAN

SHEET  
A-1.2  
PROJECT 161020  
PERMIT SET 03-04-19

**2nd FLOOR  
INVENTORY/EMPLOYEE  
GARAGE PARKING  
TIER = 49,102 SF  
GROUP "S-2"  
(246 OCCUPANTS BY AREA)  
199 PARKING STALLS**

MEANS OF EGRESS:

- TWO MEANS OF EXIT REQUIRED.
- TWO MEANS OF EXIT PROVIDED WITH DIRECT EXIT TO PUBLIC WAY (STAIR #2 & STAIR #4).
- THIRD STAIR CASE PROVIDED FOR PARKING ATTENDANT USE WITH KEY ACCESS PAD (STAIR #1).

INDICATES 2-HR. FIRE RATED PARTITION

EGRESS ANGLE  
INDICATES REQUIRED MEANS OF EGRESS

EX/EM WALL MOUNTED EMERGENCY LIGHT W/ BACK-UP BATTERY AND EXIT

IFE WALL MOUNTED FIRE EXTINGUISHER, @ LOCATIONS 1ST FLOOR (4 LOCATION AT 2ND FLOOR) = 1/2 PROVIDED

JOINT SEALANTS/DECK TRAFFIC COATING:  
LYMTAL INTERNATIONAL, INC.  
2ND FLOOR "PROVIDE" 2-HR RATED BAKER  
RODS WITH SEALANT BETWEEN TEE JOINTS.  
ULTRA BLOCK Backer Rod Mfg. Inc.  
TRAFFIC COATING: ISO-FLEX 760 U-HL VC HVT  
HEAVY DUTY DECK COATING SYSTEM  
757 ISO-FLEX PRIMER  
760 ISO-FLEX LOOK COAT ALIPHATIC "CONCRETE GREY"  
760 ISO-FLEX LOOK COAT AROMATIC "CONCRETE GREY"  
GRANUSIL 4095 MINERAL FILLERS FOR VEHICULAR TRAFFIC

